## **Bartter Enterprises Pty Limited**

EPL - 2486

## **Bartter Processing Plant**

Farm 124 Murphy Road, Hanwood NSW 2680

## Waste Water treatment Plant

Farm 126 McGann Road & Murrumbidgee Avenue, Hanwood NSW 2680

Monthly Summary November, 2015 Published 2/12/2015

## Licence condition M6.1: Daily discharge flows to water

		EPA identification point		
Date	Monitoring frequency	no. 1 Influent flow to WWTP	no. 2 Discharge to Irrigation DISCHARGE ML/DAY	no. 3 Discharge to MI
. / /20.15			1	
1/11/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
2/11/2015	Continuous	4.86*	0.00	0.00
3/11/2015	Continuous	3.57*	0.00	0.00
4/11/2015	Continuous	3.37*	0.15	0.00
5/11/2015	Continuous	2.91*	0.00	0.00
6/11/2015	Continuous	3.02*	0.00	0.00
7/11/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
8/11/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
9/11/2015	Continuous	3.74*	0.00	0.00
10/11/2015	Continuous	3.64*	0.13	0.00
11/11/2015	Continuous	3.16*	0.32	0.00
12/11/2015	Continuous	4.13*	0.00	0.00
13/11/2015	Continuous	4.17*	0.00	0.00
14/11/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
15/11/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
16/11/2015	Continuous	3.81*	0.00	0.00
17/11/2015	Continuous	3.95*	0.00	0.00
18/11/2015	Continuous	3.95*	0.14	0.00
19/11/2015	Continuous	4.11*	0.00	0.00
20/11/2015	Continuous	3.59*	0.04	0.00
21/11/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
22/11/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
23/11/2015	Continuous	3.84*	0.00	0.00
24/11/2015	Continuous	3.60*	0.00	0.00
25/11/2015	Continuous	3.39*	0.00	0.00
26/11/2015	Continuous	3.86*	0.00	0.00
27/11/2015	Continuous	4.00*	0.00	0.00
28/11/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
29/11/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
30/11/2015	Continuous	4.12*	1.21	0.00

<sup>\*</sup> Meters were broken. Data has been estimated based on the average volume of wastewater produced per bird processed.

Total Waste Water discharged to Treatment Site Not more than 1,700 mega litres of waste water in any licence period	1/11/15-30/11/2015	78.80 ML
--	--------------------	----------