

Bartter Enterprises Pty Limited

EPL - 2486

Bartter Processing Plant

Farm 124 Murphy Road, Hanwood NSW 2680

Waste Water treatment Plant

Farm 126 McGann Road & Murrumbidgee Avenue, Hanwood NSW 2680

Sample Date/time	Original result	Corrected Result	Date corrected	Date originally published	Reason
JULY-18 Flow Meter Data 26,27,28,29,31 July 2018	0 ML	1.7 ML 5.8 ML 5.8 ML 4.1 ML 2.4 ML	4/10/2018	1/08/2018	Calculation error
AUGUST-18 Flow Meter Data 11, 17, 23 August 2018	0 ML	1.9 ML 1.9 ML 2 ML	4/10/2018	6/09/2018	Calculation error
APRIL-19 MI Discharge Flow Meter Data 18,22-30/4/19	5.8 ML 6.3 ML 7.5 ML 3.5 ML 0 ML 6.63 ML 3.6 ML 3.3 ML 3.5 ML 3.1 ML	8.5 ML 7.1 ML 8.8 ML 5.2 ML 1.9 ML 8.3 ML 4.6 ML 4.9 ML 4.4 ML 4.3 ML	5/06/2019	3/05/2019	Additional discharge from alternate pump not calculated
November-19 Flow Meter Data 21/11/2019 Year to date	0.0 ML 139.6 ML	6.6ML 146.1	5/02/2020	4/12/2019	Collation error
December-19 Flow Meter Data Year to date	295 ML	301.5 ML	5/02/2020	3/01/2020	Follow on error due to collation error in November-19
May-21 Flow Meter Data 3/5/21	0.67 ML	7.62 ML	22/06/2021	1/06/2021	Calculation error