

Bartter Enterprises Pty Limited
EPL - 2486
Bartter Processing Plant
Farm 124 Murphy Road, Hanwood NSW 2680

Waste Water treatment Plant
Farm 126 McGann Road & Murrumbidgee Avenue, Hanwood NSW 2680

Monthly Summary
Published

December, 2015
6/01/2016

Licence condition M6.1: Daily discharge flows to water

Date	Monitoring frequency	EPA identification point		
		no. 1 Influent flow to WWTP	no. 2 Discharge to Irrigation	no. 3 Discharge to MI
DISCHARGE ML/DAY				
1/12/2015	Continuous	3.28*	0.00	0.00
2/12/2015	Continuous	3.2*	3.04	0.00
3/12/2015	Continuous	3.13*	0.30	0.00
4/12/2015	Continuous	3.38*	2.42	0.00
5/12/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
6/12/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
7/12/2015	Continuous	3.91*	6.27	0.00
8/12/2015	Continuous	3.65*	3.08	0.00
9/12/2015	Continuous	3.93*	0.59	0.00
10/12/2015	Continuous	3.41*	0.00	0.00
11/12/2015	Continuous	3.71*	0.00	0.00
12/12/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
13/12/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
14/12/2015	Continuous	4.14*	0.00	0.00
15/12/2015	Continuous	4.11*	4.02	0.00
16/12/2015	Continuous	4.41*	2.55	0.00
17/12/2015	Continuous	4.48*	3.45	0.00
18/12/2015	Continuous	4.07*	4.49	0.00
19/12/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
20/12/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
21/12/2015	Continuous	5.01*	4.48	0.00
22/12/2015	Continuous	4.91*	0.58	0.00
23/12/2015	Continuous	4.56*	4.16	0.00
24/12/2015	Continuous	3.09*	2.76	0.00
25/12/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
26/12/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
27/12/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
28/12/2015	Continuous	Reading not taken	Reading not taken	Reading not taken
29/12/2015	Continuous	10.14	6.83	0.00
30/12/2015	Continuous	3.29	1.34	0.00
31/12/2015	Continuous	4.11	0.71	0.88

* Meters were broken. Data has been estimated based on the average volume of wastewater produced per bird processed.

Total Waste Water discharged to Treatment Site Not more than 1,700 mega litres of waste water in any licence period	1/11/15-31/12/2015	166.66 ML
---	--------------------	------------------