

Bartter Enterprises Pty Limited
EPL - 2486
Bartter Processing Plant
Farm 124 Murphy Road, Hanwood NSW 2680

Waste Water treatment Plant
Farm 126 McGann Road & Murrumbidgee Avenue, Hanwood NSW 2680

Monthly Summary
Published

November, 2016
5/12/2016

Licence condition M6.1: Daily discharge flows to water

Date	Monitoring frequency	EPA identification point		
		no. 1 Influent flow to WWTP	no. 2 Discharge to Irrigation	no. 3 Discharge to MI
DISCHARGE ML/DAY				
1/11/2016	Continuous	4.587	0	7.57
2/11/2016	Continuous	4.635	0	8.22
3/11/2016	Continuous	5.587	0	7.42
4/11/2016	Continuous	4.81	0	6.52
5/11/2016	Continuous	READING NOT TAKEN	READING NOT TAKEN	READING NOT TAKEN
6/11/2016	Continuous	READING NOT TAKEN	READING NOT TAKEN	READING NOT TAKEN
7/11/2016	Continuous	7.22	0	22.80
8/11/2016	Continuous	4.943	0	8.02
9/11/2016	Continuous	5.411	3.26	6.93
10/11/2016	Continuous	5.30	2.49	7.80
11/11/2016	Continuous	5.44	3.99	7.90
12/11/2016	Continuous	READING NOT TAKEN	READING NOT TAKEN	READING NOT TAKEN
13/11/2016	Continuous	READING NOT TAKEN	READING NOT TAKEN	READING NOT TAKEN
14/11/2016	Continuous	6.67	0	22.06
15/11/2016	Continuous	5.318	0	7.89
16/11/2016	Continuous	4.563	0	7.3
17/11/2016	Continuous	4.72	0	1.04
18/11/2016	Continuous	5.16	23.00	0.00
19/11/2016	Continuous	READING NOT TAKEN	READING NOT TAKEN	READING NOT TAKEN
20/11/2016	Continuous	READING NOT TAKEN	READING NOT TAKEN	READING NOT TAKEN
21/11/2016	Continuous	7.46	0	0
22/11/2016	Continuous	5.113	0	0
23/11/2016	Continuous	5.317	0.04	0.00
24/11/2016	Continuous	4.91	0.00	0.00
25/11/2016	Continuous	5.42	0.00	0.00
26/11/2016	Continuous	READING NOT TAKEN	READING NOT TAKEN	READING NOT TAKEN
27/11/2016	Continuous	READING NOT TAKEN	READING NOT TAKEN	READING NOT TAKEN
28/11/2016	Continuous	6.02	0.00	0.26
29/11/2016	Continuous	5.182	0	5.74
30/11/2016	Continuous	5.144	0	4.86

Total Waste Water discharged to Treatment Site Not more than 1,700 mega litres of waste water in any licence period	1/11/16-30/11/16	118.93
---	------------------	--------