

Barter Enterprises Pty Limited
EPL - 2486
Barter Processing Plant
Farm 124 Murphy Road, Hanwood NSW 2680

Waste Water treatment Plant
Farm 126 McGann Road & Murrumbidgee Avenue, Hanwood NSW 2680

Monthly Summary January, 2016
Published 1/02/2016

Licence condition M6.1: Daily discharge flows to water

Date	Monitoring frequency	EPA identification point		
		no. 1 Influent flow to WWTP	no. 2 Discharge to Irrigation	no. 3 Discharge to MI
DISCHARGE ML/DAY				
1/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
2/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
3/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
4/01/2016	Continuous	7.39	0.02	31.61
5/01/2016	Continuous	5.18	0.00	8.21
6/01/2016	Continuous	5.01	0.00	8.35
7/01/2016	Continuous	3.71	0.00	7.60
8/01/2016	Continuous	2.43	0.00	8.14
9/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
10/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
11/01/2016	Continuous	6.82	0.00	24.04
12/01/2016	Continuous	3.09	0.00	8.24
13/01/2016	Continuous	4.23	0.00	7.71
14/01/2016	Continuous	3.55	0.00	0.00
15/01/2016	Continuous	4.53	0.00	0.00
16/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
17/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
18/01/2016	Continuous	4.89	0.00	0.00
19/01/2016	Continuous	4.52	0.25	0.00
20/01/2016	Continuous	3.73	1.86	0.00
21/01/2016	Continuous	4.01	8.01	0.00
22/01/2016	Continuous	4.40	8.94	0.00
23/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
24/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
25/01/2016	Continuous	4.71	2.82	0.00
26/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
27/01/2016	Continuous	7.46	17.68	0.00
28/01/2016	Continuous	3.15	8.25	0.00
29/01/2016	Continuous	2.62	7.11	0.00
30/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken
31/01/2016	Continuous	Reading not taken	Reading not taken	Reading not taken

Total Waste Water discharged to Treatment Site Not more than 1,700 mega litres of waste water in any licence period	1/11/15-31/1/16	252.08 ML
---	-----------------	------------------