

Bartter Enterprises Pty Limited
 EPL - 2486
Bartter Processing Plant
 Farm 124 Murphy Road, Hanwood NSW 2680

Waste Water treatment Plant
 Farm 126 McGann Road & Murrumbidgee Avenue, Hanwood NSW 2680

Yearly Summary July, 2015
 Published 29/07/2015

Licence condition M2.2: Groundwater Monitoring Requirements

Date Sampled	Date Results Received	Monitoring frequency	Pollutant	Units	EPA identification point							
					no. 12 GW 1 (5m)	no. 12 GW 1 (15m)	no. 13 GW 2 (5m)	no. 13 GW 2 (15m)	no. 14 GW 3 (5m)	no. 14 GW 3 (15m)	no. 15 GW 4 (5m)	no. 15 GW 4 (15m)
14/07/2015	28/07/2014	Yearly	Depth	meters	4.6	4.9	2.3	3.4	2	2.7	3.9	2.8
14/07/2015	28/07/2014	Yearly	Electrical Conductivity	µs/cm	17300	7300	2120	2580	2740	4330	14400	13000
14/07/2015	28/07/2014	Yearly	Nitrogen (Nitrate)	mg/L	34	2	<1	3	8	12	3	36
14/07/2015	28/07/2014	Yearly	pH	pH	7.7	7.9	8	8.3	8.1	8	7.4	7.7
14/07/2015	28/07/2014	Yearly	Total Phosphorous	mg/L	0.44	0.01	0.02	0.02	0.07	0.02	0.17	0.01
14/07/2015	28/07/2014	Yearly	Potassium (dissolved)	mg/L	112	49	39.3	24.7	40.8	41	89.5	81
14/07/2015	28/07/2014	Yearly	Sodium (dissolved)	mg/L	3440	1620	455	602	522	835	2530	2090