Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Jan-25
Published 17/02/2025

Licence condition M2.2
Discharge to waters effluent quality monitoring result
EPA identification point no. '

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
8/01/2025	15/01/2025	Weekly	Potential Hydrogen	pH	7.70	6.5 - 8.5	N
8/01/2025	15/01/2025	Weekly	Total Suspended Solids	mg/L	11	100	N
8/01/2025	15/01/2025	Weekly	Biochemical Oxygen Demand	mg/L	<5	80	N
8/01/2025	15/01/2025	Weekly	Temperature	degrees Celsius	25	30	N
8/01/2025	15/01/2025	Weekly	Nitrogen Ammonia	mg/L	66	-	-
8/01/2025	15/01/2025	Weekly	Total Nitrogen	mg/L	98	-	-
8/01/2025	15/01/2025	Weekly	Total Phosphorus	mg/L	8.9	-	-
14/01/2025	28/01/2025	Weekly	Potential Hydrogen	pH	8	6.5 - 8.5	N
14/01/2025	28/01/2025	Weekly	Total Suspended Solids	mg/L	11	100	N
14/01/2025	28/01/2025	Weekly	Biochemical Oxygen Demand	mg/L	41	80	N
14/01/2025	28/01/2025	Weekly	Temperature	degrees Celsius	27	30	N
14/01/2025	28/01/2025	Weekly	Nitrogen Ammonia	mg/L	49	-	-
14/01/2025	28/01/2025	Weekly	Total Nitrogen	mg/L	77	-	-
14/01/2025	28/01/2025	Weekly	Total Phosphorus	mg/L	8.2	-	-
21/01/2025	3/02/2025	Weekly	Potential Hydrogen	pH	7.9	6.5 - 8.5	N
21/01/2025	3/02/2025	Weekly	Total Suspended Solids	mg/L	6	100	N
21/01/2025	3/02/2025	Weekly	Biochemical Oxygen Demand	mg/L	7	80	N
21/01/2025	3/02/2025	Weekly	Temperature	degrees Celsius	23	30	N
21/01/2025	3/02/2025	Weekly	Nitrogen Ammonia	mg/L	36	-	-
21/01/2025	3/02/2025	Weekly	Total Nitrogen	mg/L	68	-	-
21/01/2025	3/02/2025	Weekly	Total Phosphorus	mg/L	3.7	-	-
29/01/2025	8/02/2025	Weekly	Potential Hydrogen	pH	7.8	6.5 - 8.5	N
29/01/2025	8/02/2025	Weekly	Total Suspended Solids	mg/L	12	100	N
29/01/2025	8/02/2025	Weekly	Biochemical Oxygen Demand	mg/L	22	80	N
29/01/2025	8/02/2025	Weekly	Temperature	degrees Celsius	27	30	N
29/01/2025	8/02/2025	Weekly	Nitrogen Ammonia	mg/L	64	-	-
29/01/2025	8/02/2025	Weekly	Total Nitrogen	mg/L	85	-	-
29/01/2025	8/02/2025	Weekly	Total Phosphorus	mg/L	4.9	-	-

Licence condition M7.1
Daily discharge flows to wate
EPA identification point no. '

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/01/2025	Continuous	2118.18	2200	N		
2/01/2025	Continuous	2124.14	2200	N		
3/01/2025	Continuous	2124.87	2200	N		
4/01/2025	Continuous	2116.05	2200	N		
5/01/2025	Continuous	2116.71	2200	N		
6/01/2025	Continuous	2118.45	2200	N		
7/01/2025	Continuous	2124.58	2200	N		
8/01/2025	Continuous	2123.33	2200	N		
9/01/2025	Continuous	2146.24	2200	N		
10/01/2025	Continuous	2108.78	2200	N		
11/01/2025	Continuous	2059.57	2200	N		
12/01/2025	Continuous	2115.15	2200	N		
13/01/2025	Continuous	2121.58	2200	N		
14/01/2025	Continuous	2120.89	2200	N		
15/01/2025	Continuous	2095.20	2200	N		
16/01/2025	Continuous	742.12	2200	N		
17/01/2025	Continuous	2074.76	2200	N		
18/01/2025	Continuous	1982.02	2200	N		
19/01/2025	Continuous	1949.66	2200	N		
20/01/2025	Continuous	2129.97	2200	N		
21/01/2025	Continuous	2089.89	2200	N		
22/01/2025	Continuous	2030.41	2200	N		
23/01/2025	Continuous	1902.17	2200	N		
24/01/2025	Continuous	1975.02	2200	N		
25/01/2025	Continuous	1952.24	2200	N		
26/01/2025	Continuous	1907.49	2200	N		
27/01/2025	Continuous	2122.58	2200	N		
28/01/2025	Continuous	2120.20	2200	N		
29/01/2025	Continuous	2122.53	2200	N		
30/01/2025	Continuous	2114.38	2200	N		
31/01/2025	Continuous	1990.88	2200	N		