Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Feb-25
Published 12/03/2025

Licence condition M2.2
Discharge to waters effluent quality monitoring result
EPA identification point no. '

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
4/02/2025	14/02/2025	Weekly	Potential Hydrogen	pH	8.00	6.5 - 8.5	N
4/02/2025	14/02/2025	Weekly	Total Suspended Solids	mg/L	10	100	N
4/02/2025	14/02/2025	Weekly	Biochemical Oxygen Demand	mg/L	46	80	N
4/02/2025	14/02/2025	Weekly	Temperature	degrees Celsius	24	30	N
4/02/2025	14/02/2025	Weekly	Nitrogen Ammonia	mg/L	34	-	-
4/02/2025	14/02/2025	Weekly	Total Nitrogen	mg/L	84	-	-
4/02/2025	14/02/2025	Weekly	Total Phosphorus	mg/L	6.1	-	-
11/02/2025	18/02/2025	Weekly	Potential Hydrogen	pH	7.7	6.5 - 8.5	N
11/02/2025	18/02/2025	Weekly	Total Suspended Solids	mg/L	19	100	N
11/02/2025	18/02/2025	Weekly	Biochemical Oxygen Demand	mg/L	62	80	N
11/02/2025	18/02/2025	Weekly	Temperature	degrees Celsius	24	30	N
11/02/2025	18/02/2025	Weekly	Nitrogen Ammonia	mg/L	39	-	-
11/02/2025	18/02/2025	Weekly	Total Nitrogen	mg/L	93	-	-
11/02/2025	18/02/2025	Weekly	Total Phosphorus	mg/L	5.8	-	-
18/02/2025	27/02/2025	Weekly	Potential Hydrogen	pH	7.9	6.5 - 8.5	N
18/02/2025	27/02/2025	Weekly	Total Suspended Solids	mg/L	5	100	N
18/02/2025	27/02/2025	Weekly	Biochemical Oxygen Demand	mg/L	24	80	N
18/02/2025	27/02/2025	Weekly	Temperature	degrees Celsius	24	30	N
18/02/2025	27/02/2025	Weekly	Nitrogen Ammonia	mg/L	38	-	-
18/02/2025	27/02/2025	Weekly	Total Nitrogen	mg/L	96	-	-
18/02/2025	27/02/2025	Weekly	Total Phosphorus	mg/L	2.2	-	-
25/02/2025	5/03/2025	Weekly	Potential Hydrogen	pH	7.6	6.5 - 8.5	N
25/02/2025	5/03/2025	Weekly	Total Suspended Solids	mg/L	5	100	N
25/02/2025	5/03/2025	Weekly	Biochemical Oxygen Demand	mg/L	33	80	N
25/02/2025	5/03/2025	Weekly	Temperature	degrees Celsius	26	30	N
25/02/2025	5/03/2025	Weekly	Nitrogen Ammonia	mg/L	42	-	-
25/02/2025	5/03/2025	Weekly	Total Nitrogen	mg/L	100	-	-
25/02/2025	5/03/2025	Weekly	Total Phosphorus	mg/L	15	-	-

Licence condition M7.1
Daily discharge flows to wate
EPA identification point no. '

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/02/2025	Continuous	2033.32	2200	N		
2/02/2025	Continuous	2047.80	2200	N		
3/02/2025	Continuous	1961.38	2200	N		
4/02/2025	Continuous	2128.93	2200	N		
5/02/2025	Continuous	2093.23	2200	N		
6/02/2025	Continuous	2117.99	2200	N		
7/02/2025	Continuous	2142.30	2200	N		
8/02/2025	Continuous	1889.29	2200	N		
9/02/2025	Continuous	1786.99	2200	N		
10/02/2025	Continuous	1753.33	2200	N		
11/02/2025	Continuous	2189.48	2200	N		
12/02/2025	Continuous	2092.36	2200	N		
13/02/2025	Continuous	2124.19	2200	N		
14/02/2025	Continuous	2119.85	2200	N		
15/02/2025	Continuous	2120.68	2200	N		
16/02/2025	Continuous	2034.14	2200	N		
17/02/2025	Continuous	2146.70	2200	N		
18/02/2025	Continuous	2165.61	2200	N		
19/02/2025	Continuous	2101.82	2200	N		
20/02/2025	Continuous	2120.75	2200	N		
21/02/2025	Continuous	2179.11	2200	N		
22/02/2025	Continuous	2116.53	2200	N		
23/02/2025	Continuous	2123.97	2200	N		
24/02/2025	Continuous	2123.97	2200	N		
25/02/2025	Continuous	2177.24	2200	N		
26/02/2025	Continuous	2119.51	2200	N		
27/02/2025	Continuous	2115.20	2200	N		
28/02/2025	Continuous	2114.36	2200	N		