Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Mar-25
Published 4/04/2025

Licence condition M2.2
Discharge to waters effluent quality monitoring result
EPA identification point no. '

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
3/03/2025	11/03/2025	Weekly	Potential Hydrogen	pH	7.6	6.5 - 8.5	N
3/03/2025	11/03/2025	Weekly	Total Suspended Solids	mg/L	6	100	N
3/03/2025	11/03/2025	Weekly	Biochemical Oxygen Demand	mg/L	38	80	N
3/03/2025	11/03/2025	Weekly	Temperature	degrees Celsius	26	30	N
3/03/2025	11/03/2025	Weekly	Nitrogen Ammonia	mg/L	36	-	-
3/03/2025	11/03/2025	Weekly	Total Nitrogen	mg/L	93	-	-
3/03/2025	11/03/2025	Weekly	Total Phosphorus	mg/L	16	-	-
11/03/2025	19/03/2025	Weekly	Potential Hydrogen	pH	7.4	6.5 - 8.5	N
11/03/2025	19/03/2025	Weekly	Total Suspended Solids	mg/L	12	100	N
11/03/2025	19/03/2025	Weekly	Biochemical Oxygen Demand	mg/L	83	80	Y
11/03/2025	19/03/2025	Weekly	Temperature	degrees Celsius	24	30	N
11/03/2025	19/03/2025	Weekly	Nitrogen Ammonia	mg/L	42	-	-
11/03/2025	19/03/2025	Weekly	Total Nitrogen	mg/L	87	-	-
11/03/2025	19/03/2025	Weekly	Total Phosphorus	mg/L	11	-	-
18/03/2025	26/03/2025	Weekly	Potential Hydrogen	pH	7.7	6.5 - 8.5	N
18/03/2025	26/03/2025	Weekly	Total Suspended Solids	mg/L	20	100	N
18/03/2025	26/03/2025	Weekly	Biochemical Oxygen Demand	mg/L	98	80	Y
18/03/2025	26/03/2025	Weekly	Temperature	degrees Celsius	23	30	N
18/03/2025	26/03/2025	Weekly	Nitrogen Ammonia	mg/L	61	-	-
18/03/2025	26/03/2025	Weekly	Total Nitrogen	mg/L	110	-	-
18/03/2025	26/03/2025	Weekly	Total Phosphorus	mg/L	24	-	-
25/03/2025	2/04/2025	Weekly	Potential Hydrogen	pH	7.4	6.5 - 8.5	N
25/03/2025	2/04/2025	Weekly	Total Suspended Solids	mg/L	18	100	N
25/03/2025	2/04/2025	Weekly	Biochemical Oxygen Demand	mg/L	21	80	N
25/03/2025	2/04/2025	Weekly	Temperature	degrees Celsius	25	30	N
25/03/2025	2/04/2025	Weekly	Nitrogen Ammonia	mg/L	14	-	-
25/03/2025	2/04/2025	Weekly	Total Nitrogen	mg/L	69	-	-
25/03/2025	2/04/2025	Weekly	Total Phosphorus	mg/L	5.1	-	-

Licence condition M7.1
Daily discharge flows to wate
EPA identification point no. '

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/03/2025	Continuous	2107.49	2200	N		
2/03/2025	Continuous	2100.10	2200	N		
3/03/2025	Continuous	2131.26	2200	N		
4/03/2025	Continuous	2191.94	2200	N		
5/03/2025	Continuous	2143.87	2200	N		
6/03/2025	Continuous	2127.99	2200	N		
7/03/2025	Continuous	2122.81	2200	N		
8/03/2025	Continuous	2108.73	2200	N		
9/03/2025	Continuous	2157.07	2200	N		
10/03/2025	Continuous	2129.48	2200	N		
11/03/2025	Continuous	2130.70	2200	N		
12/03/2025	Continuous	2128.39	2200	N		
13/03/2025	Continuous	2143.04	2200	N		
14/03/2025	Continuous	2123.74	2200	N		
15/03/2025	Continuous	2107.51	2200	N		
16/03/2025	Continuous	2123.19	2200	N		
17/03/2025	Continuous	2130.44	2200	N		
18/03/2025	Continuous	2128.55	2200	N		
19/03/2025	Continuous	2129.78	2200	N		
20/03/2025	Continuous	2137.79	2200	N		
21/03/2025	Continuous	2135.52	2200	N		
22/03/2025	Continuous	2129.33	2200	N		
23/03/2025	Continuous	2114.65	2200	N		
24/03/2025	Continuous	2125.09	2200	N		
25/03/2025	Continuous	2141.54	2200	N		
26/03/2025	Continuous	2146.84	2200	N		
27/03/2025	Continuous	2128.99	2200	N		
28/03/2025	Continuous	2183.65	2200	N		
29/03/2025	Continuous	2143.05	2200	N		
30/03/2025	Continuous	2132.16	2200	N		
31/03/2025	Continuous	2124.29	2200	N		