Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary May-25
Published 12/06/2025

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
6/05/2025	15/05/2025	Weekly	Potential Hydrogen	pH	7.00	6.5 - 8.5	
6/05/2025	15/05/2025	Weekly	Total Suspended Solids	mg/L	14	100	
6/05/2025	15/05/2025	Weekly	Biochemical Oxygen Demand	mg/L	16	80	
6/05/2025	15/05/2025	Weekly	Temperature	degrees Celsius	21	30	
6/05/2025	15/05/2025	Weekly	Nitrogen Ammonia	mg/L	7.1	-	
6/05/2025	15/05/2025	Weekly	Total Nitrogen	mg/L	52	-	
6/05/2025	15/05/2025	Weekly	Total Phosphorus	mg/L	5.5	-	
13/05/2025	27/05/2025	Weekly	Potential Hydrogen	pH	8.4	6.5 - 8.5	
13/05/2025	27/05/2025	Weekly	Total Suspended Solids	mg/L	7	100	
13/05/2025	27/05/2025	Weekly	Biochemical Oxygen Demand	mg/L	8	80	
13/05/2025	27/05/2025	Weekly	Temperature	degrees Celsius	22	30	
13/05/2025	27/05/2025	Weekly	Nitrogen Ammonia	mg/L	6.4	-	
13/05/2025	27/05/2025	Weekly	Total Nitrogen	mg/L	38.0	-	
13/05/2025	27/05/2025	Weekly	Total Phosphorus	mg/L	2.1	-	
20/05/2025	30/05/2025	Weekly	Potential Hydrogen	pH	8	6.5 - 8.5	
20/05/2025	30/05/2025	Weekly	Total Suspended Solids	mg/L	25	100	
20/05/2025	30/05/2025	Weekly	Biochemical Oxygen Demand	mg/L	22	80	
20/05/2025	30/05/2025	Weekly	Temperature	degrees Celsius	21	30	
20/05/2025	30/05/2025	Weekly	Nitrogen Ammonia	mg/L	46	-	
20/05/2025	30/05/2025	Weekly	Total Nitrogen	mg/L	74	-	
20/05/2025	30/05/2025	Weekly	Total Phosphorus	mg/L	14	-	
27/05/2025	5/06/2025	Weekly	Potential Hydrogen	pH	8	6.5 - 8.5	
27/05/2025	5/06/2025	Weekly	Total Suspended Solids	mg/L	7	100	
27/05/2025	5/06/2025	Weekly	Biochemical Oxygen Demand	mg/L	24	80	
27/05/2025	5/06/2025	Weekly	Temperature	degrees Celsius	19	30	
27/05/2025	5/06/2025	Weekly	Nitrogen Ammonia	mg/L	5	-	
27/05/2025	5/06/2025	Weekly	Total Nitrogen	mg/L	38	-	
27/05/2025	5/06/2025	Weekly	Total Phosphorus	mg/L	5.9	-	

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/05/2025	Continuous	2280.24	2200	Y		
2/05/2025	Continuous	2269.03	2200	Y		
3/05/2025	Continuous	2119.66	2200	N		
4/05/2025	Continuous	2116.80	2200	N		
5/05/2025	Continuous	2121.83	2200	N		
6/05/2025	Continuous	2126.15	2200	N		
7/05/2025	Continuous	2118.76	2200	N		
8/05/2025	Continuous	2122.89	2200	N		
9/05/2025	Continuous	2119.25	2200	N		
10/05/2025	Continuous	2133.19	2200	N		
11/05/2025	Continuous	2121.77	2200	N		
12/05/2025	Continuous	2120.07	2200	N		
13/05/2025	Continuous	2128.39	2200	N		
14/05/2025	Continuous	2124.24	2200	N		
15/05/2025	Continuous	2125.63	2200	N		
16/05/2025	Continuous	2121.59	2200	N		
17/05/2025	Continuous	2186.08	2200	N		
18/05/2025	Continuous	2192.57	2200	N		
19/05/2025	Continuous	2908.86	2200	Y		
20/05/2025	Continuous	4122.29	2200	Y		
21/05/2025	Continuous	6188.57	2200	Y		
22/05/2025	Continuous	6298.87	2200	Y		
23/05/2025	Continuous	7484.67	2200	Y		
24/05/2025	Continuous	7290.27	2200	Y		
25/05/2025	Continuous	2136.82	2200	N		
26/05/2025	Continuous	1684.27	2200	N		
27/05/2025	Continuous	2128.86	2200	N		
28/05/2025	Continuous	2117.52	2200	N		
29/05/2025	Continuous	2124.83	2200	N		
30/05/2025	Continuous	2121.35	2200	N		
31/05/2025	Continuous	2129.87	2200	N		