Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Jun-25
Published 16/07/2025

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
3/06/2025	12/06/2025	Weekly	Potential Hydrogen	pH	7.40	6.5 - 8.5	N
3/06/2025	12/06/2025	Weekly	Total Suspended Solids	mg/L	12	100	N
3/06/2025	12/06/2025	Weekly	Biochemical Oxygen Demand	mg/L	38	80	N
3/06/2025	12/06/2025	Weekly	Temperature	degrees Celsius	18	30	N
3/06/2025	12/06/2025	Weekly	Nitrogen Ammonia	mg/L	4.1	-	-
3/06/2025	12/06/2025	Weekly	Total Nitrogen	mg/L	33	-	-
3/06/2025	12/06/2025	Weekly	Total Phosphorus	mg/L	5.6	-	-
10/06/2025	18/06/2025	Weekly	Potential Hydrogen	pH	7	6.5 - 8.5	N
10/06/2025	18/06/2025	Weekly	Total Suspended Solids	mg/L	9	100	N
10/06/2025	18/06/2025	Weekly	Biochemical Oxygen Demand	mg/L	34	80	N
10/06/2025	18/06/2025	Weekly	Temperature	degrees Celsius	14	30	N
10/06/2025	18/06/2025	Weekly	Nitrogen Ammonia	mg/L	5.3	-	-
10/06/2025	18/06/2025	Weekly	Total Nitrogen	mg/L	38	-	-
10/06/2025	18/06/2025	Weekly	Total Phosphorus	mg/L	5	-	-
17/06/2025	25/06/2025	Weekly	Potential Hydrogen	pH	7.2	6.5 - 8.5	N
17/06/2025	25/06/2025	Weekly	Total Suspended Solids	mg/L	<5	100	N
17/06/2025	25/06/2025	Weekly	Biochemical Oxygen Demand	mg/L	25	80	N
17/06/2025	25/06/2025	Weekly	Temperature	degrees Celsius	15	30	N
17/06/2025	25/06/2025	Weekly	Nitrogen Ammonia	mg/L	40	-	-
17/06/2025	25/06/2025	Weekly	Total Nitrogen	mg/L	43	-	-
17/06/2025	25/06/2025	Weekly	Total Phosphorus	mg/L	17	-	-
24/06/2025	3/07/2025	Weekly	Potential Hydrogen	pH	7.2	6.5 - 8.5	N
24/06/2025	3/07/2025	Weekly	Total Suspended Solids	mg/L	<5	100	N
24/06/2025	3/07/2025	Weekly	Biochemical Oxygen Demand	mg/L	19	80	N
24/06/2025	3/07/2025	Weekly	Temperature	degrees Celsius	18	30	N
24/06/2025	3/07/2025	Weekly	Nitrogen Ammonia	mg/L	41	-	-
24/06/2025	3/07/2025	Weekly	Total Nitrogen	mg/L	45	-	-
24/06/2025	3/07/2025	Weekly	Total Phosphorus	mg/L	13	-	-
30/06/2025	8/07/2025	Weekly	Potential Hydrogen	pH	7	6.5 - 8.5	N
30/06/2025	8/07/2025	Weekly	Total Suspended Solids	mg/L	23	100	N
30/06/2025	8/07/2025	Weekly	Biochemical Oxygen Demand	mg/L	30	80	N
30/06/2025	8/07/2025	Weekly	Temperature	degrees Celsius	16	30	N
30/06/2025	8/07/2025	Weekly	Nitrogen Ammonia	mg/L	59	-	-
30/06/2025	8/07/2025	Weekly	Total Nitrogen	mg/L	84	-	-
30/06/2025	8/07/2025	Weekly	Total Phosphorus	mg/L	26	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/06/2025	Continuous	2159.23	2200	N		
2/06/2025	Continuous	2129.36	2200	N		
3/06/2025	Continuous	2163.74	2200	N		
4/06/2025	Continuous	2124.32	2200	N		
5/06/2025	Continuous	2119.96	2200	N		
6/06/2025	Continuous	2129.24	2200	N		
7/06/2025	Continuous	2127.85	2200	N		
8/06/2025	Continuous	2166.67	2200	N		
9/06/2025	Continuous	2146.17	2200	N		
10/06/2025	Continuous	2027.87	2200	N		
11/06/2025	Continuous	2037.77	2200	N		
12/06/2025	Continuous	2121.79	2200	N		
13/06/2025	Continuous	2125.06	2200	N		
14/06/2025	Continuous	2124.61	2200	N		
15/06/2025	Continuous	2187.97	2200	N		
16/06/2025	Continuous	2141.63	2200	N		
17/06/2025	Continuous	2179.10	2200	N		
18/06/2025	Continuous	2123.33	2200	N		
19/06/2025	Continuous	2145.44	2200	N		
20/06/2025	Continuous	2120.58	2200	N		
21/06/2025	Continuous	2129.11	2200	N		
22/06/2025	Continuous	2115.25	2200	N		
23/06/2025	Continuous	2113.16	2200	N		
24/06/2025	Continuous	2149.05	2200	N		
25/06/2025	Continuous	2132.05	2200	N		
26/06/2025	Continuous	2126.08	2200	N		
27/06/2025	Continuous	2122.01	2200	N		
28/06/2025	Continuous	2124.68	2200	N		
29/06/2025	Continuous	2120.14	2200	N		
30/06/2025	Continuous	2059.21	2200	N		