Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Jul-25
Published 26/08/2025

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
8/07/2025	15/07/2025	Weekly	Potential Hydrogen	pH	7.10	6.5 - 8.5	N
8/07/2025	15/07/2025	Weekly	Total Suspended Solids	mg/L	6	100	N
8/07/2025	15/07/2025	Weekly	Biochemical Oxygen Demand	mg/L	39	80	N
8/07/2025	15/07/2025	Weekly	Temperature	degrees Celsius	16	30	N
8/07/2025	15/07/2025	Weekly	Nitrogen Ammonia	mg/L	82	-	-
8/07/2025	15/07/2025	Weekly	Total Nitrogen	mg/L	83	-	-
8/07/2025	15/07/2025	Weekly	Total Phosphorus	mg/L	2.9	-	-
16/07/2025	23/07/2025	Weekly	Potential Hydrogen	pH	7.2	6.5 - 8.5	N
16/07/2025	23/07/2025	Weekly	Total Suspended Solids	mg/L	9	100	N
16/07/2025	23/07/2025	Weekly	Biochemical Oxygen Demand	mg/L	52	80	N
16/07/2025	23/07/2025	Weekly	Temperature	degrees Celsius	15	30	N
16/07/2025	23/07/2025	Weekly	Nitrogen Ammonia	mg/L	51	-	-
16/07/2025	23/07/2025	Weekly	Total Nitrogen	mg/L	58	-	-
16/07/2025	23/07/2025	Weekly	Total Phosphorus	mg/L	38	-	-
22/07/2025	29/07/2025	Weekly	Potential Hydrogen	pH	7.2	6.5 - 8.5	N
22/07/2025	29/07/2025	Weekly	Total Suspended Solids	mg/L	9	100	N
22/07/2025	29/07/2025	Weekly	Biochemical Oxygen Demand	mg/L	71	80	N
22/07/2025	29/07/2025	Weekly	Temperature	degrees Celsius	16	30	N
22/07/2025	29/07/2025	Weekly	Nitrogen Ammonia	mg/L	71	-	-
22/07/2025	29/07/2025	Weekly	Total Nitrogen	mg/L	88	-	-
22/07/2025	29/07/2025	Weekly	Total Phosphorus	mg/L	6.4	-	-
29/07/2025	5/08/2025	Weekly	Potential Hydrogen	pH	7.2	6.5 - 8.5	N
29/07/2025	5/08/2025	Weekly	Total Suspended Solids	mg/L	7	100	N
29/07/2025	5/08/2025	Weekly	Biochemical Oxygen Demand	mg/L	46	80	N
29/07/2025	5/08/2025	Weekly	Temperature	degrees Celsius	14	30	N
29/07/2025	5/08/2025	Weekly	Nitrogen Ammonia	mg/L	44	-	-
29/07/2025	5/08/2025	Weekly	Total Nitrogen	mg/L	70	-	-
29/07/2025	5/08/2025	Weekly	Total Phosphorus	mg/L	0.74	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/07/2025	Continuous	2121.98	2200	N		
2/07/2025	Continuous	2080.50	2200	N		
3/07/2025	Continuous	2119.32	2200	N		
4/07/2025	Continuous	2100.05	2200	N		
5/07/2025	Continuous	2102.98	2200	N		
6/07/2025	Continuous	2133.25	2200	N		
7/07/2025	Continuous	2131.77	2200	N		
8/07/2025	Continuous	2115.26	2200	N		
9/07/2025	Continuous	2066.42	2200	N		
10/07/2025	Continuous	2145.96	2200	N		
11/07/2025	Continuous	2138.28	2200	N		
12/07/2025	Continuous	2125.68	2200	N		
13/07/2025	Continuous	2131.98	2200	N		
14/07/2025	Continuous	2122.59	2200	N		
15/07/2025	Continuous	2127.91	2200	N		
16/07/2025	Continuous	1999.82	2200	N		
17/07/2025	Continuous	2131.47	2200	N		
18/07/2025	Continuous	2136.01	2200	N		
19/07/2025	Continuous	2124.67	2200	N		
20/07/2025	Continuous	2179.20	2200	N		
21/07/2025	Continuous	2123.35	2200	N		
22/07/2025	Continuous	1234.41	2200	N		
23/07/2025	Continuous	2090.58	2200	N		
24/07/2025	Continuous	2471.59	2200	Y		
25/07/2025	Continuous	2479.90	2200	Y		
26/07/2025	Continuous	2485.63	2200	Y		
27/07/2025	Continuous	2122.41	2200	N		
28/07/2025	Continuous	2128.83	2200	N		
29/07/2025	Continuous	2128.85	2200	N		
30/07/2025	Continuous	2134.88	2200	N		
31/07/2025	Continuous	2125.01	2200	N		