Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Aug-25
Published 9/09/2025

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
5/08/2025	13/08/2025	Weekly	Potential Hydrogen	pH	7.60	6.5 - 8.5	N
5/08/2025	13/08/2025	Weekly	Total Suspended Solids	mg/L	23	100	N
5/08/2025	13/08/2025	Weekly	Biochemical Oxygen Demand	mg/L	100	80	Y
5/08/2025	13/08/2025	Weekly	Temperature	degrees Celsius	18	30	N
5/08/2025	13/08/2025	Weekly	Nitrogen Ammonia	mg/L	47	-	-
5/08/2025	13/08/2025	Weekly	Total Nitrogen	mg/L	67	-	-
5/08/2025	13/08/2025	Weekly	Total Phosphorus	mg/L	8.4	-	-
12/08/2025	20/08/2025	Weekly	Potential Hydrogen	pH	7.40	6.5 - 8.5	N
12/08/2025	20/08/2025	Weekly	Total Suspended Solids	mg/L	14	100	N
12/08/2025	20/08/2025	Weekly	Biochemical Oxygen Demand	mg/L	89	80	Y
12/08/2025	20/08/2025	Weekly	Temperature	degrees Celsius	16	30	N
12/08/2025	20/08/2025	Weekly	Nitrogen Ammonia	mg/L	37	-	-
12/08/2025	20/08/2025	Weekly	Total Nitrogen	mg/L	66	-	-
12/08/2025	20/08/2025	Weekly	Total Phosphorus	mg/L	4.1	-	-
19/08/2025	27/08/2025	Weekly	Potential Hydrogen	pH	7.20	6.5 - 8.5	N
19/08/2025	27/08/2025	Weekly	Total Suspended Solids	mg/L	18	100	N
19/08/2025	27/08/2025	Weekly	Biochemical Oxygen Demand	mg/L	65	80	N
19/08/2025	27/08/2025	Weekly	Temperature	degrees Celsius	16	30	N
19/08/2025	27/08/2025	Weekly	Nitrogen Ammonia	mg/L	50	-	-
19/08/2025	27/08/2025	Weekly	Total Nitrogen	mg/L	80	-	-
19/08/2025	27/08/2025	Weekly	Total Phosphorus	mg/L	4.1	-	-
26/08/2025	3/09/2025	Weekly	Potential Hydrogen	pH	7.00	6.5 - 8.5	N
26/08/2025	3/09/2025	Weekly	Total Suspended Solids	mg/L	9	100	N
26/08/2025	3/09/2025	Weekly	Biochemical Oxygen Demand	mg/L	120	80	N
26/08/2025	3/09/2025	Weekly	Temperature	degrees Celsius	19	30	N
26/08/2025	3/09/2025	Weekly	Nitrogen Ammonia	mg/L	48	-	-
26/08/2025	3/09/2025	Weekly	Total Nitrogen	mg/L	70	-	-
26/08/2025	3/09/2025	Weekly	Total Phosphorus	mg/L	4.0	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/08/2025	Continuous	2129.76	2200	N		
2/08/2025	Continuous	2501.29	2200	Y		
3/08/2025	Continuous	3713.29	2200	Y		
4/08/2025	Continuous	2762.56	2200	Y		
5/08/2025	Continuous	2658.26	2200	Y		
6/08/2025	Continuous	2139.40	2200	N		
7/08/2025	Continuous	2186.15	2200	N		
8/08/2025	Continuous	2190.00	2200	N		
9/08/2025	Continuous	2195.38	2200	N		
10/08/2025	Continuous	2118.43	2200	N		
11/08/2025	Continuous	2117.09	2200	N		
12/08/2025	Continuous	2115.78	2200	N		
13/08/2025	Continuous	2121.44	2200	N		
14/08/2025	Continuous	2288.02	2200	Y		
15/08/2025	Continuous	2376.17	2200	Y		
16/08/2025	Continuous	2144.63	2200	N		
17/08/2025	Continuous	2113.13	2200	N		
18/08/2025	Continuous	2144.63	2200	N		
19/08/2025	Continuous	996.14	2200	N		
20/08/2025	Continuous	2121.91	2200	N		
21/08/2025	Continuous	2120.83	2200	N		
22/08/2025	Continuous	2133.22	2200	N		
23/08/2025	Continuous	2129.28	2200	N		
24/08/2025	Continuous	2122.06	2200	N		
25/08/2025	Continuous	2114.97	2200	N		
26/08/2025	Continuous	2109.89	2200	N		
27/08/2025	Continuous	2112.82	2200	N		
28/08/2025	Continuous	2112.10	2200	N		
29/08/2025	Continuous	2116.97	2200	N		
30/08/2025	Continuous	2166.90	2200	N		
31/08/2025	Continuous	2122.38	2200	N		