Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Sep-25
Published 21/10/2025

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
2/09/2025	9/09/2025	Weekly	Potential Hydrogen	pH	7.10	6.5 - 8.5	N
2/09/2025	9/09/2025	Weekly	Total Suspended Solids	mg/L	33	100	N
2/09/2025	9/09/2025	Weekly	Biochemical Oxygen Demand	mg/L	120	80	Y
2/09/2025	9/09/2025	Weekly	Temperature	degrees Celsius	17	30	N
2/09/2025	9/09/2025	Weekly	Nitrogen Ammonia	mg/L	53	-	-
2/09/2025	9/09/2025	Weekly	Total Nitrogen	mg/L	77	-	-
2/09/2025	9/09/2025	Weekly	Total Phosphorus	mg/L	1.3	-	-
9/09/2025	15/09/2025	Weekly	Potential Hydrogen	pH	7.20	6.5 - 8.5	N
9/09/2025	15/09/2025	Weekly	Total Suspended Solids	mg/L	30	100	N
9/09/2025	15/09/2025	Weekly	Biochemical Oxygen Demand	mg/L	79	80	N
9/09/2025	15/09/2025	Weekly	Temperature	degrees Celsius	20	30	N
9/09/2025	15/09/2025	Weekly	Nitrogen Ammonia	mg/L	56	-	-
9/09/2025	15/09/2025	Weekly	Total Nitrogen	mg/L	76	-	-
9/09/2025	15/09/2025	Weekly	Total Phosphorus	mg/L	2.7	-	-
16/09/2025	24/09/2025	Weekly	Potential Hydrogen	pH	7.30	6.5 - 8.5	N
16/09/2025	24/09/2025	Weekly	Total Suspended Solids	mg/L	<5	100	N
16/09/2025	24/09/2025	Weekly	Biochemical Oxygen Demand	mg/L	74	80	N
16/09/2025	24/09/2025	Weekly	Temperature	degrees Celsius	20	30	N
16/09/2025	24/09/2025	Weekly	Nitrogen Ammonia	mg/L	37	-	-
16/09/2025	24/09/2025	Weekly	Total Nitrogen	mg/L	68	-	-
16/09/2025	24/09/2025	Weekly	Total Phosphorus	mg/L	8.6	-	-
23/09/2025	1/10/2025	Weekly	Potential Hydrogen	pH	7.40	6.5 - 8.5	N
23/09/2025	1/10/2025	Weekly	Total Suspended Solids	mg/L	19	100	N
23/09/2025	1/10/2025	Weekly	Biochemical Oxygen Demand	mg/L	91	80	Y
23/09/2025	1/10/2025	Weekly	Temperature	degrees Celsius	19	30	N
23/09/2025	1/10/2025	Weekly	Nitrogen Ammonia	mg/L	35	-	-
23/09/2025	1/10/2025	Weekly	Total Nitrogen	mg/L	55	-	-
23/09/2025	1/10/2025	Weekly	Total Phosphorus	mg/L	0.4	-	-
30/09/2025	9/10/2025	Weekly	Potential Hydrogen	pH	6.80	6.5 - 8.5	N
30/09/2025	9/10/2025	Weekly	Total Suspended Solids	mg/L	9	100	N
30/09/2025	9/10/2025	Weekly	Biochemical Oxygen Demand	mg/L	73	80	N
30/09/2025	9/10/2025	Weekly	Temperature	degrees Celsius	26.8	30	N
30/09/2025	9/10/2025	Weekly	Nitrogen Ammonia	mg/L	41	-	-
30/09/2025	9/10/2025	Weekly	Total Nitrogen	mg/L	62	-	-
30/09/2025	9/10/2025	Weekly	Total Phosphorus	mg/L	0.87	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/09/2025	Continuous	2140.33	2200	N		
2/09/2025	Continuous	2115.53	2200	N		
3/09/2025	Continuous	2112.76	2200	N		
4/09/2025	Continuous	2113.74	2200	N		
5/09/2025	Continuous	2108.51	2200	N		
6/09/2025	Continuous	2115.25	2200	N		
7/09/2025	Continuous	2118.02	2200	N		
8/09/2025	Continuous	2127.60	2200	N		
9/09/2025	Continuous	2150.57	2200	N		
10/09/2025	Continuous	2125.95	2200	N		
11/09/2025	Continuous	2122.45	2200	N		
12/09/2025	Continuous	2112.17	2200	N		
13/09/2025	Continuous	2114.67	2200	N		
14/09/2025	Continuous	2098.66	2200	N		
15/09/2025	Continuous	2117.88	2200	N		
16/09/2025	Continuous	2122.78	2200	N		
17/09/2025	Continuous	2145.31	2200	N		
18/09/2025	Continuous	1778.21	2200	N		
19/09/2025	Continuous	2107.59	2200	N		
20/09/2025	Continuous	2069.93	2200	N		
21/09/2025	Continuous	2140.38	2200	N		
22/09/2025	Continuous	2129.18	2200	N		
23/09/2025	Continuous	2121.26	2200	N		
24/09/2025	Continuous	2144.44	2200	N		
25/09/2025	Continuous	2160.30	2200	N		
26/09/2025	Continuous	2227.60	2200	Y		
27/09/2025	Continuous	2193.39	2200	N		
28/09/2025	Continuous	2149.48	2200	N		
29/09/2025	Continuous	2124.79	2200	N		
30/09/2025	Continuous	2130.73	2200	N		