Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Nov-25
Published

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
4/11/2025	12/11/2025	Weekly	Potential Hydrogen	pH	7.50	6.5 - 8.5	N
4/11/2025	12/11/2025	Weekly	Total Suspended Solids	mg/L	15	100	N
4/11/2025	12/11/2025	Weekly	Biochemical Oxygen Demand	mg/L	150	80	Y
4/11/2025	12/11/2025	Weekly	Temperature	degrees Celsius	23	30	N
4/11/2025	12/11/2025	Weekly	Nitrogen Ammonia	mg/L	62	-	-
4/11/2025	12/11/2025	Weekly	Total Nitrogen	mg/L	79	-	-
4/11/2025	12/11/2025	Weekly	Total Phosphorus	mg/L	2.6	-	-
11/11/2025	19/11/2025	Weekly	Potential Hydrogen	pH	7.40	6.5 - 8.5	N
11/11/2025	19/11/2025	Weekly	Total Suspended Solids	mg/L	6	100	N
11/11/2025	19/11/2025	Weekly	Biochemical Oxygen Demand	mg/L	91	80	Y
11/11/2025	19/11/2025	Weekly	Temperature	degrees Celsius	22	30	N
11/11/2025	19/11/2025	Weekly	Nitrogen Ammonia	mg/L	71	-	-
11/11/2025	19/11/2025	Weekly	Total Nitrogen	mg/L	100	-	-
11/11/2025	19/11/2025	Weekly	Total Phosphorus	mg/L	0.5	-	-
18/11/2025	26/11/2025	Weekly	Potential Hydrogen	pH	7.70	6.5 - 8.5	N
18/11/2025	26/11/2025	Weekly	Total Suspended Solids	mg/L	21	100	N
18/11/2025	26/11/2025	Weekly	Biochemical Oxygen Demand	mg/L	350	80	Y
18/11/2025	26/11/2025	Weekly	Temperature	degrees Celsius	22	30	N
18/11/2025	26/11/2025	Weekly	Nitrogen Ammonia	mg/L	100	-	-
18/11/2025	26/11/2025	Weekly	Total Nitrogen	mg/L	140	-	-
18/11/2025	26/11/2025	Weekly	Total Phosphorus	mg/L	9.7	-	-
25/11/2025	4/12/2025	Weekly	Potential Hydrogen	pH	7.40	6.5 - 8.5	N
25/11/2025	4/12/2025	Weekly	Total Suspended Solids	mg/L	17	100	N
25/11/2025	4/12/2025	Weekly	Biochemical Oxygen Demand	mg/L	63	80	N
25/11/2025	4/12/2025	Weekly	Temperature	degrees Celsius	25	30	N
25/11/2025	4/12/2025	Weekly	Nitrogen Ammonia	mg/L	97	-	-
25/11/2025	4/12/2025	Weekly	Total Nitrogen	mg/L	120	-	-
25/11/2025	4/12/2025	Weekly	Total Phosphorus	mg/L	12	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/11/2025	Continuous	2184.24	2200	N		
2/11/2025	Continuous	2178.87	2200	N		
3/11/2025	Continuous	2145.63	2200	N		
4/11/2025	Continuous	2147.07	2200	N		
5/11/2025	Continuous	2149.24	2200	N		
6/11/2025	Continuous	2144.84	2200	N		
7/11/2025	Continuous	2146.16	2200	N		
8/11/2025	Continuous	2168.89	2200	N		
9/11/2025	Continuous	2107.51	2200	N		
10/11/2025	Continuous	2122.48	2200	N		
11/11/2025	Continuous	2135.97	2200	N		
12/11/2025	Continuous	1802.46	2200	N		
13/11/2025	Continuous	2092.93	2200	N		
14/11/2025	Continuous	2152.83	2200	N		
15/11/2025	Continuous	2129.92	2200	N		
16/11/2025	Continuous	2132.68	2200	N		
17/11/2025	Continuous	2176.98	2200	N		
18/11/2025	Continuous	2174.86	2200	N		
19/11/2025	Continuous	2134.27	2200	N		
20/11/2025	Continuous	2153.95	2200	N		
21/11/2025	Continuous	2150.86	2200	N		
22/11/2025	Continuous	2130.27	2200	N		
23/11/2025	Continuous	2126.74	2200	N		
24/11/2025	Continuous	2122.81	2200	N		
25/11/2025	Continuous	2175.59	2200	N		
26/11/2025	Continuous	2184.91	2200	N		
27/11/2025	Continuous	2123.95	2200	N		
28/11/2025	Continuous	1884.31	2200	N		
29/11/2025	Continuous	2176.31	2200	N		
30/11/2025	Continuous	2101.94	2200	N		