Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Dec-25
Published

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
2/12/2025	9/12/2025	Weekly	Potential Hydrogen	pH	7.50	6.5 - 8.5	N
2/12/2025	9/12/2025	Weekly	Total Suspended Solids	mg/L	16	100	N
2/12/2025	9/12/2025	Weekly	Biochemical Oxygen Demand	mg/L	220	80	Y
2/12/2025	9/12/2025	Weekly	Temperature	degrees Celsius	22	30	N
2/12/2025	9/12/2025	Weekly	Nitrogen Ammonia	mg/L	110	-	-
2/12/2025	9/12/2025	Weekly	Total Nitrogen	mg/L	140	-	-
2/12/2025	9/12/2025	Weekly	Total Phosphorus	mg/L	7.0	-	-
9/12/2025	17/12/2025	Weekly	Potential Hydrogen	pH	7.40	6.5 - 8.5	N
9/12/2025	17/12/2025	Weekly	Total Suspended Solids	mg/L	13	100	N
9/12/2025	17/12/2025	Weekly	Biochemical Oxygen Demand	mg/L	86	80	Y
9/12/2025	17/12/2025	Weekly	Temperature	degrees Celsius	25	30	N
9/12/2025	17/12/2025	Weekly	Nitrogen Ammonia	mg/L	96	-	-
9/12/2025	17/12/2025	Weekly	Total Nitrogen	mg/L	130	-	-
9/12/2025	17/12/2025	Weekly	Total Phosphorus	mg/L	4.8	-	-
19/12/2025	6/01/2026	Weekly	Potential Hydrogen	pH	7.30	6.5 - 8.5	N
19/12/2025	6/01/2026	Weekly	Total Suspended Solids	mg/L	15	100	N
19/12/2025	6/01/2026	Weekly	Biochemical Oxygen Demand	mg/L	54	80	N
19/12/2025	6/01/2026	Weekly	Temperature	degrees Celsius	26	30	N
19/12/2025	6/01/2026	Weekly	Nitrogen Ammonia	mg/L	47	-	-
19/12/2025	6/01/2026	Weekly	Total Nitrogen	mg/L	58	-	-
19/12/2025	6/01/2026	Weekly	Total Phosphorus	mg/L	3.0	-	-
22/12/2025	7/01/2026	Weekly	Potential Hydrogen	pH	7.90	6.5 - 8.5	N
22/12/2025	7/01/2026	Weekly	Total Suspended Solids	mg/L	18	100	N
22/12/2025	7/01/2026	Weekly	Biochemical Oxygen Demand	mg/L	220	80	Y
22/12/2025	7/01/2026	Weekly	Temperature	degrees Celsius	28	30	N
22/12/2025	7/01/2026	Weekly	Nitrogen Ammonia	mg/L	45	-	-
22/12/2025	7/01/2026	Weekly	Total Nitrogen	mg/L	73	-	-
22/12/2025	7/01/2026	Weekly	Total Phosphorus	mg/L	5.0	-	-
31/12/2025	13/01/2026	Weekly	Potential Hydrogen	pH	7.50	6.5 - 8.5	N
31/12/2025	13/01/2026	Weekly	Total Suspended Solids	mg/L	27	100	N
31/12/2025	13/01/2026	Weekly	Biochemical Oxygen Demand	mg/L	47	80	N
31/12/2025	13/01/2026	Weekly	Temperature	degrees Celsius	24.8	30	N
31/12/2025	13/01/2026	Weekly	Nitrogen Ammonia	mg/L	21	-	-
31/12/2025	13/01/2026	Weekly	Total Nitrogen	mg/L	44	-	-
31/12/2025	13/01/2026	Weekly	Total Phosphorus	mg/L	2.3	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/12/2025	Continuous	2130.20	2200	N		
2/12/2025	Continuous	2119.73	2200	N		
3/12/2025	Continuous	2119.99	2200	N		
4/12/2025	Continuous	2106.02	2200	N		
5/12/2025	Continuous	2096.24	2200	N		
6/12/2025	Continuous	2147.10	2200	N		
7/12/2025	Continuous	2099.45	2200	N		
8/12/2025	Continuous	2140.32	2200	N		
9/12/2025	Continuous	2135.53	2200	N		
10/12/2025	Continuous	2127.24	2200	N		
11/12/2025	Continuous	2084.85	2200	N		
12/12/2025	Continuous	2121.76	2200	N		
13/12/2025	Continuous	2123.22	2200	N		
14/12/2025	Continuous	1913.16	2200	N		
15/12/2025	Continuous	2067.92	2200	N		
16/12/2025	Continuous	2154.11	2200	N		
17/12/2025	Continuous	1830.54	2200	N		
18/12/2025	Continuous	2117.97	2200	N		
19/12/2025	Continuous	2200.20	2200	Y		
20/12/2025	Continuous	2798.38	2200	Y		
21/12/2025	Continuous	2590.71	2200	Y		
22/12/2025	Continuous	2154.61	2200	N		
23/12/2025	Continuous	2150.61	2200	N		
24/12/2025	Continuous	2103.21	2200	N		
25/12/2025	Continuous	2125.39	2200	N		
26/12/2025	Continuous	2127.24	2200	N		
27/12/2025	Continuous	2142.89	2200	N		
28/12/2025	Continuous	2158.82	2200	N		
29/12/2025	Continuous	2151.45	2200	N		
30/12/2025	Continuous	2145.02	2200	N		
31/12/2025	Continuous	2155.13	2200	N		