Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Apr-26
Published

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
7/04/2026	15/04/2026	Weekly	Potential Hydrogen	pH	7.30	6.5 - 8.5	N
7/04/2026	15/04/2026	Weekly	Total Suspended Solids	mg/L	22	100	N
7/04/2026	15/04/2026	Weekly	Biochemical Oxygen Demand	mg/L	10	80	N
7/04/2026	15/04/2026	Weekly	Temperature	degrees Celsius	22	30	N
7/04/2026	15/04/2026	Weekly	Nitrogen Ammonia	mg/L	0.57	-	-
7/04/2026	15/04/2026	Weekly	Total Nitrogen	mg/L	47	-	-
7/04/2026	15/04/2026	Weekly	Total Phosphorus	mg/L	3.5	-	-
14/04/2026	23/04/2026	Weekly	Potential Hydrogen	pH	7.20	6.5 - 8.5	N
14/04/2026	23/04/2026	Weekly	Total Suspended Solids	mg/L	11	100	N
14/04/2026	23/04/2026	Weekly	Biochemical Oxygen Demand	mg/L	10	80	N
14/04/2026	23/04/2026	Weekly	Temperature	degrees Celsius	20	30	N
14/04/2026	23/04/2026	Weekly	Nitrogen Ammonia	mg/L	0.23	-	-
14/04/2026	23/04/2026	Weekly	Total Nitrogen	mg/L	57	-	-
14/04/2026	23/04/2026	Weekly	Total Phosphorus	mg/L	3.6	-	-
21/04/2026	30/04/2026	Weekly	Potential Hydrogen	pH	7.20	6.5 - 8.5	N
21/04/2026	30/04/2026	Weekly	Total Suspended Solids	mg/L	9	100	N
21/04/2026	30/04/2026	Weekly	Biochemical Oxygen Demand	mg/L	11	80	N
21/04/2026	30/04/2026	Weekly	Temperature	degrees Celsius	21	30	N
21/04/2026	30/04/2026	Weekly	Nitrogen Ammonia	mg/L	0.73	-	-
21/04/2026	30/04/2026	Weekly	Total Nitrogen	mg/L	42	-	-
21/04/2026	30/04/2026	Weekly	Total Phosphorus	mg/L	3.4	-	-
28/04/2026	6/05/2026	Weekly	Potential Hydrogen	pH	7.20	6.5 - 8.5	N
28/04/2026	6/05/2026	Weekly	Total Suspended Solids	mg/L	12	100	N
28/04/2026	6/05/2026	Weekly	Biochemical Oxygen Demand	mg/L	<5	80	N
28/04/2026	6/05/2026	Weekly	Temperature	degrees Celsius	21	30	N
28/04/2026	6/05/2026	Weekly	Nitrogen Ammonia	mg/L	0.54	-	-
28/04/2026	6/05/2026	Weekly	Total Nitrogen	mg/L	43	-	-
28/04/2026	6/05/2026	Weekly	Total Phosphorus	mg/L	2.4	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/04/2026	Continuous	2124.51	2200	N		
2/04/2026	Continuous	2136.49	2200	N		
3/04/2026	Continuous	2178.14	2200	N		
4/04/2026	Continuous	2144.29	2200	N		
5/04/2026	Continuous	2154.63	2200	N		
6/04/2026	Continuous	2156.07	2200	N		
7/04/2026	Continuous	2149.15	2200	N		
8/04/2026	Continuous	2139.02	2200	N		
9/04/2026	Continuous	2150.38	2200	N		
10/04/2026	Continuous	2144.66	2200	N		
11/04/2026	Continuous	2178.68	2200	N		
12/04/2026	Continuous	1413.90	2200	N		
13/04/2026	Continuous	2144.32	2200	N		
14/04/2026	Continuous	2048.62	2200	N		
15/04/2026	Continuous	2133.88	2200	N		
16/04/2026	Continuous	2013.03	2200	N		
17/04/2026	Continuous	2163.58	2200	N		
18/04/2026	Continuous	2190.02	2200	N		
19/04/2026	Continuous	2177.41	2200	N		
20/04/2026	Continuous	2154.55	2200	N		
21/04/2026	Continuous	1990.42	2200	N		
22/04/2026	Continuous	2136.40	2200	N		
23/04/2026	Continuous	2139.39	2200	N		
24/04/2026	Continuous	2137.17	2200	N		
25/04/2026	Continuous	2146.99	2200	N		
26/04/2026	Continuous	2196.88	2200	N		
27/04/2026	Continuous	2180.75	2200	N		
28/04/2026	Continuous	2152.35	2200	N		
29/04/2026	Continuous	2153.60	2200	N		
30/04/2026	Continuous	2144.64	2200	N		