Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Feb-26
Published

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
3/02/2026	11/02/2026	Weekly	Potential Hydrogen	pH	7.00	6.5 - 8.5	N
3/02/2026	11/02/2026	Weekly	Total Suspended Solids	mg/L	14	100	N
3/02/2026	11/02/2026	Weekly	Biochemical Oxygen Demand	mg/L	24	80	N
3/02/2026	11/02/2026	Weekly	Temperature	degrees Celsius	24	30	N
3/02/2026	11/02/2026	Weekly	Nitrogen Ammonia	mg/L	2.6	-	-
3/02/2026	11/02/2026	Weekly	Total Nitrogen	mg/L	41	-	-
3/02/2026	11/02/2026	Weekly	Total Phosphorus	mg/L	2.1	-	-
10/02/2026	19/02/2026	Weekly	Potential Hydrogen	pH	7.10	6.5 - 8.5	N
10/02/2026	19/02/2026	Weekly	Total Suspended Solids	mg/L	58	100	N
10/02/2026	19/02/2026	Weekly	Biochemical Oxygen Demand	mg/L	33	80	N
10/02/2026	19/02/2026	Weekly	Temperature	degrees Celsius	26	30	N
10/02/2026	19/02/2026	Weekly	Nitrogen Ammonia	mg/L	0.22	-	-
10/02/2026	19/02/2026	Weekly	Total Nitrogen	mg/L	36	-	-
10/02/2026	19/02/2026	Weekly	Total Phosphorus	mg/L	4.8	-	-
17/02/2026	25/02/2026	Weekly	Potential Hydrogen	pH	6.90	6.5 - 8.5	N
17/02/2026	25/02/2026	Weekly	Total Suspended Solids	mg/L	13	100	N
17/02/2026	25/02/2026	Weekly	Biochemical Oxygen Demand	mg/L	20	80	N
17/02/2026	25/02/2026	Weekly	Temperature	degrees Celsius	24	30	N
17/02/2026	25/02/2026	Weekly	Nitrogen Ammonia	mg/L	0.97	-	-
17/02/2026	25/02/2026	Weekly	Total Nitrogen	mg/L	30	-	-
17/02/2026	25/02/2026	Weekly	Total Phosphorus	mg/L	2.7	-	-
24/02/2026	4/03/2026	Weekly	Potential Hydrogen	pH	7.10	6.5 - 8.5	N
24/02/2026	4/03/2026	Weekly	Total Suspended Solids	mg/L	28	100	N
24/02/2026	4/03/2026	Weekly	Biochemical Oxygen Demand	mg/L	15	80	N
24/02/2026	4/03/2026	Weekly	Temperature	degrees Celsius	28	30	N
24/02/2026	4/03/2026	Weekly	Nitrogen Ammonia	mg/L	0.94	-	-
24/02/2026	4/03/2026	Weekly	Total Nitrogen	mg/L	34	-	-
24/02/2026	4/03/2026	Weekly	Total Phosphorus	mg/L	4.5	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/02/2026	Continuous	2184.42	2200	N		
2/02/2026	Continuous	2160.29	2200	N		
3/02/2026	Continuous	2157.55	2200	N		
4/02/2026	Continuous	2188.10	2200	N		
5/02/2026	Continuous	2188.11	2200	N		
6/02/2026	Continuous	2133.98	2200	N		
7/02/2026	Continuous	2164.21	2200	N		
8/02/2026	Continuous	2128.58	2200	N		
9/02/2026	Continuous	2180.00	2200	N		
10/02/2026	Continuous	2158.82	2200	N		
11/02/2026	Continuous	2146.61	2200	N		
12/02/2026	Continuous	2171.10	2200	N		
13/02/2026	Continuous	2124.40	2200	N		
14/02/2026	Continuous	2125.84	2200	N		
15/02/2026	Continuous	2125.68	2200	N		
16/02/2026	Continuous	2165.86	2200	N		
17/02/2026	Continuous	2149.05	2200	N		
18/02/2026	Continuous	2144.25	2200	N		
19/02/2026	Continuous	2164.40	2200	N		
20/02/2026	Continuous	2150.27	2200	N		
21/02/2026	Continuous	2154.23	2200	N		
22/02/2026	Continuous	2153.73	2200	N		
23/02/2026	Continuous	2164.03	2200	N		
24/02/2026	Continuous	2145.28	2200	N		
25/02/2026	Continuous	2159.28	2200	N		
26/02/2026	Continuous	2140.28	2200	N		
27/02/2026	Continuous	2146.01	2200	N		
28/02/2026	Continuous	2145.23	2200	N		