Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Published: Jan-26

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
6/01/2026	14/01/2026	Weekly	Potential Hydrogen	pH	7.10	6.5 - 8.5	N
6/01/2026	14/01/2026	Weekly	Total Suspended Solids	mg/L	25	100	N
6/01/2026	14/01/2026	Weekly	Biochemical Oxygen Demand	mg/L	14	80	N
6/01/2026	14/01/2026	Weekly	Temperature	degrees Celsius	29.4	30	N
6/01/2026	14/01/2026	Weekly	Nitrogen Ammonia	mg/L	2.5	-	-
6/01/2026	14/01/2026	Weekly	Total Nitrogen	mg/L	22	-	-
6/01/2026	14/01/2026	Weekly	Total Phosphorus	mg/L	2.3	-	-
13/01/2026	20/01/2026	Weekly	Potential Hydrogen	pH	7.30	6.5 - 8.5	N
13/01/2026	20/01/2026	Weekly	Total Suspended Solids	mg/L	44	100	N
13/01/2026	20/01/2026	Weekly	Biochemical Oxygen Demand	mg/L	150	80	Y
13/01/2026	20/01/2026	Weekly	Temperature	degrees Celsius	27	30	N
13/01/2026	20/01/2026	Weekly	Nitrogen Ammonia	mg/L	11	-	-
13/01/2026	20/01/2026	Weekly	Total Nitrogen	mg/L	38	-	-
13/01/2026	20/01/2026	Weekly	Total Phosphorus	mg/L	4	-	-
20/01/2026	29/01/2026	Weekly	Potential Hydrogen	pH	7.30	6.5 - 8.5	N
20/01/2026	29/01/2026	Weekly	Total Suspended Solids	mg/L	19	100	N
20/01/2026	29/01/2026	Weekly	Biochemical Oxygen Demand	mg/L	<5	80	N
20/01/2026	29/01/2026	Weekly	Temperature	degrees Celsius	25	30	N
20/01/2026	29/01/2026	Weekly	Nitrogen Ammonia	mg/L	6.5	-	-
20/01/2026	29/01/2026	Weekly	Total Nitrogen	mg/L	26	-	-
20/01/2026	29/01/2026	Weekly	Total Phosphorus	mg/L	2.0	-	-
27/01/2026	4/02/2026	Weekly	Potential Hydrogen	pH	7.60	6.5 - 8.5	N
27/01/2026	4/02/2026	Weekly	Total Suspended Solids	mg/L	12	100	N
27/01/2026	4/02/2026	Weekly	Biochemical Oxygen Demand	mg/L	76	80	N
27/01/2026	4/02/2026	Weekly	Temperature	degrees Celsius	26.9	30	N
27/01/2026	4/02/2026	Weekly	Nitrogen Ammonia	mg/L	6.1	-	-
27/01/2026	4/02/2026	Weekly	Total Nitrogen	mg/L	44	-	-
27/01/2026	4/02/2026	Weekly	Total Phosphorus	mg/L	3.1	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/01/2026	Continuous	2160.13	2200	N		
2/01/2026	Continuous	2157.52	2200	N		
3/01/2026	Continuous	2168.30	2200	N		
4/01/2026	Continuous	2199.50	2200	N		
5/01/2026	Continuous	2152.21	2200	N		
6/01/2026	Continuous	2149.15	2200	N		
7/01/2026	Continuous	2149.15	2200	N		
8/01/2026	Continuous	2115.99	2200	N		
9/01/2026	Continuous	2107.04	2200	N		
10/01/2026	Continuous	2109.08	2200	N		
11/01/2026	Continuous	2137.21	2200	N		
12/01/2026	Continuous	2195.75	2200	N		
13/01/2026	Continuous	2172.78	2200	N		
14/01/2026	Continuous	2148.60	2200	N		
15/01/2026	Continuous	2167.58	2200	N		
16/01/2026	Continuous	2167.58	2200	N		
17/01/2026	Continuous	2149.08	2200	N		
18/01/2026	Continuous	2140.33	2200	N		
19/01/2026	Continuous	2069.60	2200	N		
20/01/2026	Continuous	2137.12	2200	N		
21/01/2026	Continuous	2156.15	2200	N		
22/01/2026	Continuous	2142.62	2200	N		
23/01/2026	Continuous	2148.37	2200	N		
24/01/2026	Continuous	2144.13	2200	N		
25/01/2026	Continuous	2151.44	2200	N		
26/01/2026	Continuous	2134.84	2200	N		
27/01/2026	Continuous	2164.14	2200	N		
28/01/2026	Continuous	2195.81	2200	N		
29/01/2026	Continuous	2216.58	2200	Y		
30/01/2026	Continuous	2140.93	2200	N		
31/01/2026	Continuous	2148.99	2200	N		