Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary May-26
Published 17/06/2026

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
4/05/2026	12/05/2026	Weekly	Potential Hydrogen	pH	7.10	6.5 - 8.5	N
4/05/2026	12/05/2026	Weekly	Total Suspended Solids	mg/L	200	100	Y
4/05/2026	12/05/2026	Weekly	Biochemical Oxygen Demand	mg/L	32	80	N
4/05/2026	12/05/2026	Weekly	Temperature	degrees Celsius	23	30	N
4/05/2026	12/05/2026	Weekly	Nitrogen Ammonia	mg/L	1.4	-	-
4/05/2026	12/05/2026	Weekly	Total Nitrogen	mg/L	48	-	-
4/05/2026	12/05/2026	Weekly	Total Phosphorus	mg/L	7.6	-	-
12/05/2026	20/05/2026	Weekly	Potential Hydrogen	pH	8.00	6.5 - 8.5	N
12/05/2026	20/05/2026	Weekly	Total Suspended Solids	mg/L	12	100	N
12/05/2026	20/05/2026	Weekly	Biochemical Oxygen Demand	mg/L	19	80	N
12/05/2026	20/05/2026	Weekly	Temperature	degrees Celsius	20	30	N
12/05/2026	20/05/2026	Weekly	Nitrogen Ammonia	mg/L	2.1	-	-
12/05/2026	20/05/2026	Weekly	Total Nitrogen	mg/L	59	-	-
12/05/2026	20/05/2026	Weekly	Total Phosphorus	mg/L	3.2	-	-
19/05/2026	26/05/2026	Weekly	Potential Hydrogen	pH	7.20	6.5 - 8.5	N
19/05/2026	26/05/2026	Weekly	Total Suspended Solids	mg/L	10	100	N
19/05/2026	26/05/2026	Weekly	Biochemical Oxygen Demand	mg/L	34	80	N
19/05/2026	26/05/2026	Weekly	Temperature	degrees Celsius	21	30	N
19/05/2026	26/05/2026	Weekly	Nitrogen Ammonia	mg/L	11	-	-
19/05/2026	26/05/2026	Weekly	Total Nitrogen	mg/L	43	-	-
19/05/2026	26/05/2026	Weekly	Total Phosphorus	mg/L	2.5	-	-
26/05/2026	3/06/2026	Weekly	Potential Hydrogen	pH	7.30	6.5 - 8.5	N
26/05/2026	3/06/2026	Weekly	Total Suspended Solids	mg/L	26	100	N
26/05/2026	3/06/2026	Weekly	Biochemical Oxygen Demand	mg/L	49	80	N
26/05/2026	3/06/2026	Weekly	Temperature	degrees Celsius	22	30	N
26/05/2026	3/06/2026	Weekly	Nitrogen Ammonia	mg/L	19	-	-
26/05/2026	3/06/2026	Weekly	Total Nitrogen	mg/L	39	-	-
26/05/2026	3/06/2026	Weekly	Total Phosphorus	mg/L	5.8	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/05/2026	Continuous	2137.30	2200	N		
2/05/2026	Continuous	2154.39	2200	N		
3/05/2026	Continuous	2140.93	2200	N		
4/05/2026	Continuous	2173.22	2200	N		
5/05/2026	Continuous	2185.38	2200	N		
6/05/2026	Continuous	2175.25	2200	N		
7/05/2026	Continuous	2173.16	2200	N		
8/05/2026	Continuous	2130.35	2200	N		
9/05/2026	Continuous	2127.02	2200	N		
10/05/2026	Continuous	2136.61	2200	N		
11/05/2026	Continuous	2189.30	2200	N		
12/05/2026	Continuous	2185.88	2200	N		
13/05/2026	Continuous	2138.14	2200	N		
14/05/2026	Continuous	2078.75	2200	N		
15/05/2026	Continuous	2134.86	2200	N		
16/05/2026	Continuous	2131.73	2200	N		
17/05/2026	Continuous	2135.00	2200	N		
18/05/2026	Continuous	2145.90	2200	N		
19/05/2026	Continuous	2142.58	2200	N		
20/05/2026	Continuous	2106.72	2200	N		
21/05/2026	Continuous	2185.69	2200	N		
22/05/2026	Continuous	2134.31	2200	N		
23/05/2026	Continuous	2240.66	2200	Y		
24/05/2026	Continuous	2136.70	2200	N		
25/05/2026	Continuous	2151.13	2200	N		
26/05/2026	Continuous	2133.79	2200	N		
27/05/2026	Continuous	2135.21	2200	N		
28/05/2026	Continuous	2134.47	2200	N		
29/05/2026	Continuous	2127.84	2200	N		
30/05/2026	Continuous	2135.88	2200	N		
31/05/2026	Continuous	1555.54	2200	N		