Bartter Enterprises Pty Limited
Hawthorne St, Beresfield NSW 2322
EPL: 1329

Monthly Summary Jul-26
Published

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

Date Sampled	Date obtained	Monitoring frequency	Pollutant	Units	Analysis result	100 percentile concentration limit	Exceedance (Y/N)
7/07/2026	15/07/2026	Weekly	Potential Hydrogen	pH	7.40	6.5 - 8.5	N
7/07/2026	15/07/2026	Weekly	Total Suspended Solids	mg/L	7	100	N
7/07/2026	15/07/2026	Weekly	Biochemical Oxygen Demand	mg/L	9	80	N
7/07/2026	15/07/2026	Weekly	Temperature	degrees Celsius	17	30	N
7/07/2026	15/07/2026	Weekly	Nitrogen Ammonia	mg/L	0.14	-	-
7/07/2026	15/07/2026	Weekly	Total Nitrogen	mg/L	27	-	-
7/07/2026	15/07/2026	Weekly	Total Phosphorus	mg/L	4.4	-	-
14/07/2026	22/07/2026	Weekly	Potential Hydrogen	pH	8.70	6.5 - 8.5	Y
14/07/2026	22/07/2026	Weekly	Total Suspended Solids	mg/L	9	100	N
14/07/2026	22/07/2026	Weekly	Biochemical Oxygen Demand	mg/L	6	80	N
14/07/2026	22/07/2026	Weekly	Temperature	degrees Celsius	17	30	N
14/07/2026	22/07/2026	Weekly	Nitrogen Ammonia	mg/L	0.15	-	-
14/07/2026	22/07/2026	Weekly	Total Nitrogen	mg/L	30	-	-
14/07/2026	22/07/2026	Weekly	Total Phosphorus	mg/L	3.9	-	-
21/07/2026	29/07/2026	Weekly	Potential Hydrogen	pH	7.00	6.5 - 8.5	N
21/07/2026	29/07/2026	Weekly	Total Suspended Solids	mg/L	5	100	N
21/07/2026	29/07/2026	Weekly	Biochemical Oxygen Demand	mg/L	<5	80	N
21/07/2026	29/07/2026	Weekly	Temperature	degrees Celsius	16	30	N
21/07/2026	29/07/2026	Weekly	Nitrogen Ammonia	mg/L	0.2	-	-
21/07/2026	29/07/2026	Weekly	Total Nitrogen	mg/L	36	-	-
21/07/2026	29/07/2026	Weekly	Total Phosphorus	mg/L	2.4	-	-
28/07/2026	5/08/2026	Weekly	Potential Hydrogen	pH	7.50	6.5 - 8.5	N
28/07/2026	5/08/2026	Weekly	Total Suspended Solids	mg/L	18	100	N
28/07/2026	5/08/2026	Weekly	Biochemical Oxygen Demand	mg/L	<5	80	N
28/07/2026	5/08/2026	Weekly	Temperature	degrees Celsius	15	30	N
28/07/2026	5/08/2026	Weekly	Nitrogen Ammonia	mg/L	0.47	-	-
28/07/2026	5/08/2026	Weekly	Total Nitrogen	mg/L	49	-	-
28/07/2026	5/08/2026	Weekly	Total Phosphorus	mg/L	3.7	-	-

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

Date	Monitoring frequency	Discharge (kL/day)	Volume/Mass limit (kL/day)	Exceedance (Y/N)		
1/07/2026	Continuous	2145.55	2200	N		
2/07/2026	Continuous	2149.72	2200	N		
3/07/2026	Continuous	2139.51	2200	N		
4/07/2026	Continuous	2134.72	2200	N		
5/07/2026	Continuous	1978.57	2200	N		
6/07/2026	Continuous	2147.39	2200	N		
7/07/2026	Continuous	2120.44	2200	N		
8/07/2026	Continuous	2125.81	2200	N		
9/07/2026	Continuous	2120.32	2200	N		
10/07/2026	Continuous	2109.49	2200	N		
11/07/2026	Continuous	2121.84	2200	N		
12/07/2026	Continuous	2118.98	2200	N		
13/07/2026	Continuous	2098.83	2200	N		
14/07/2026	Continuous	2102.58	2200	N		
15/07/2026	Continuous	2143.66	2200	N		
16/07/2026	Continuous	2150.65	2200	N		
17/07/2026	Continuous	1869.69	2200	N		
18/07/2026	Continuous	2188.08	2200	N		
19/07/2026	Continuous	2150.63	2200	N		
20/07/2026	Continuous	2166.70	2200	N		
21/07/2026	Continuous	2134.21	2200	N		
22/07/2026	Continuous	2122.04	2200	N		
23/07/2026	Continuous	2055.02	2200	N		
24/07/2026	Continuous	1063.98	2200	N		
25/07/2026	Continuous	2153.52	2200	N		
26/07/2026	Continuous	2120.02	2200	N		
27/07/2026	Continuous	2122.71	2200	N		
28/07/2026	Continuous	2133.38	2200	N		
29/07/2026	Continuous	2130.89	2200	N		
30/07/2026	Continuous	2113.69	2200	N		
31/07/2026	Continuous	2144.95	2200	N		