**Bartter Enterprises Pty Limited**
Hawthorne St, Beresfield NSW 2322
**EPL: 1329**

Monthly Summary Jun-26
Published

Licence condition M2.2
Discharge to waters effluent quality monitoring results
EPA identification point no. 1

| Date Sampled | Date obtained | Monitoring frequency | Pollutant | Units | Analysis result | 100 percentile concentration limit | Exceedance (Y/N) |
|---|---|---|---|---|---|---|---|
| 1/06/2026 | 10/06/2026 | Weekly | Potential Hydrogen | pH | 7.50 | 6.5 - 8.5 | N |
| 1/06/2026 | 10/06/2026 | Weekly | Total Suspended Solids | mg/L | 8 | 100 | N |
| 1/06/2026 | 10/06/2026 | Weekly | Biochemical Oxygen Demand | mg/L | 20 | 80 | N |
| 1/06/2026 | 10/06/2026 | Weekly | Temperature | degrees Celsius | 18 | 30 | N |
| 1/06/2026 | 10/06/2026 | Weekly | Nitrogen Ammonia | mg/L | 6.6 | - | - |
| 1/06/2026 | 10/06/2026 | Weekly | Total Nitrogen | mg/L | 40 | - | - |
| 1/06/2026 | 10/06/2026 | Weekly | Total Phosphorus | mg/L | 3.0 | - | - |
| 9/06/2026 | 17/06/2026 | Weekly | Potential Hydrogen | pH | 7.30 | 6.5 - 8.5 | N |
| 9/06/2026 | 17/06/2026 | Weekly | Total Suspended Solids | mg/L | 5 | 100 | N |
| 9/06/2026 | 17/06/2026 | Weekly | Biochemical Oxygen Demand | mg/L | <5 | 80 | N |
| 9/06/2026 | 17/06/2026 | Weekly | Temperature | degrees Celsius | 17 | 30 | N |
| 9/06/2026 | 17/06/2026 | Weekly | Nitrogen Ammonia | mg/L | 3.3 | - | - |
| 9/06/2026 | 17/06/2026 | Weekly | Total Nitrogen | mg/L | 51 | - | - |
| 9/06/2026 | 17/06/2026 | Weekly | Total Phosphorus | mg/L | 6.5 | - | - |
| 16/06/2026 | 24/06/2026 | Weekly | Potential Hydrogen | pH | 7.60 | 6.5 - 8.5 | N |
| 16/06/2026 | 24/06/2026 | Weekly | Total Suspended Solids | mg/L | 10 | 100 | N |
| 16/06/2026 | 24/06/2026 | Weekly | Biochemical Oxygen Demand | mg/L | 10 | 80 | N |
| 16/06/2026 | 24/06/2026 | Weekly | Temperature | degrees Celsius | 19 | 30 | N |
| 16/06/2026 | 24/06/2026 | Weekly | Nitrogen Ammonia | mg/L | 0.68 | - | - |
| 16/06/2026 | 24/06/2026 | Weekly | Total Nitrogen | mg/L | 37 | - | - |
| 16/06/2026 | 24/06/2026 | Weekly | Total Phosphorus | mg/L | 9.9 | - | - |
| 23/06/2026 | 1/07/2026 | Weekly | Potential Hydrogen | pH | 7.00 | 6.5 - 8.5 | N |
| 23/06/2026 | 1/07/2026 | Weekly | Total Suspended Solids | mg/L | 6 | 100 | N |
| 23/06/2026 | 1/07/2026 | Weekly | Biochemical Oxygen Demand | mg/L | 20 | 80 | N |
| 23/06/2026 | 1/07/2026 | Weekly | Temperature | degrees Celsius | 15.5 | 30 | N |
| 23/06/2026 | 1/07/2026 | Weekly | Nitrogen Ammonia | mg/L | 3.6 | - | - |
| 23/06/2026 | 1/07/2026 | Weekly | Total Nitrogen | mg/L | 60 | - | - |
| 23/06/2026 | 1/07/2026 | Weekly | Total Phosphorus | mg/L | 4.9 | - | - |
| 30/06/2026 | 8/07/2026 | Weekly | Potential Hydrogen | pH | 7.30 | 6.5 - 8.5 | N |
| 30/06/2026 | 8/07/2026 | Weekly | Total Suspended Solids | mg/L | 13 | 100 | N |
| 30/06/2026 | 8/07/2026 | Weekly | Biochemical Oxygen Demand | mg/L | <5 | 80 | N |
| 30/06/2026 | 8/07/2026 | Weekly | Temperature | degrees Celsius | 18 | 30 | N |
| 30/06/2026 | 8/07/2026 | Weekly | Nitrogen Ammonia | mg/L | 0.99 | - | - |
| 30/06/2026 | 8/07/2026 | Weekly | Total Nitrogen | mg/L | 40 | - | - |
| 30/06/2026 | 8/07/2026 | Weekly | Total Phosphorus | mg/L | 2.9 | - | - |

Licence condition M7.1
Daily discharge flows to water
EPA identification point no. 1

| Date | Monitoring frequency | Discharge (kL/day) | Volume/Mass limit (kL/day) | Exceedance (Y/N) | | |
|---|---|---|---|---|---|---|
| 1/06/2026 | Continuous | 2135.52 | 2200 | N | | |
| 2/06/2026 | Continuous | 2138.31 | 2200 | N | | |
| 3/06/2026 | Continuous | 2133.69 | 2200 | N | | |
| 4/06/2026 | Continuous | 2154.92 | 2200 | N | | |
| 5/06/2026 | Continuous | 2174.87 | 2200 | N | | |
| 6/06/2026 | Continuous | 2182.41 | 2200 | N | | |
| 7/06/2026 | Continuous | 2136.59 | 2200 | N | | |
| 8/06/2026 | Continuous | 2146.52 | 2200 | N | | |
| 9/06/2026 | Continuous | 2145.04 | 2200 | N | | |
| 10/06/2026 | Continuous | 1854.28 | 2200 | N | | |
| 11/06/2026 | Continuous | 2136.73 | 2200 | N | | |
| 12/06/2026 | Continuous | 2134.93 | 2200 | N | | |
| 13/06/2026 | Continuous | 2166.66 | 2200 | N | | |
| 14/06/2026 | Continuous | 1863.01 | 2200 | N | | |
| 15/06/2026 | Continuous | 2126.54 | 2200 | N | | |
| 16/06/2026 | Continuous | 1992.44 | 2200 | N | | |
| 17/06/2026 | Continuous | 1355.46 | 2200 | N | | |
| 18/06/2026 | Continuous | 2139.61 | 2200 | N | | |
| 19/06/2026 | Continuous | 2143.51 | 2200 | N | | |
| 20/06/2026 | Continuous | 2135.17 | 2200 | N | | |
| 21/06/2026 | Continuous | 2177.93 | 2200 | N | | |
| 22/06/2026 | Continuous | 2174.48 | 2200 | N | | |
| 23/06/2026 | Continuous | 2142.74 | 2200 | N | | |
| 24/06/2026 | Continuous | 2149.77 | 2200 | N | | |
| 25/06/2026 | Continuous | 2188.66 | 2200 | N | | |
| 26/06/2026 | Continuous | 2143.45 | 2200 | N | | |
| 27/06/2026 | Continuous | 2130.84 | 2200 | N | | |
| 28/06/2026 | Continuous | 2135.16 | 2200 | N | | |
| 29/06/2026 | Continuous | 2195.08 | 2200 | N | | |
| 30/06/2026 | Continuous | 2194.98 | 2200 | N | | |